



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Randi Wheeler
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109**

1/24/2017

Phone: (856) 616-9516
Fax: (586) 616-9517

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 1/3/2017. The results are tabulated on the attached data pages for the following client designated project:

Pt. Pleasant - Ocean Road

The reference number for these samples is EMSL Order #011700025. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 187

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011700025
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Randi Wheeler**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 01/03/17 10:00 AM

Project: **Pt. Pleasant - Ocean Road**

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0001</i>	
38-1229-0C01 Mens Bathroom Sink Near Boiler Room								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0002</i>	
38-1229-0C02 Kitchen Sink (36)								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	6.80	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0003</i>	
38-1229-0C03 Kitchen Sink (38)								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	2.96	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0004</i>	
38-1229-0C04 Kitchen Sink (39)								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	1.28	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0005</i>	
38-1229-0C05 Room 151 Sink (41)								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0006</i>	
38-1229-0C06 Room 303 Sink (42)								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0007</i>	
38-1229-0C07 Room 303 Bathroom Sink (43)								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011700025
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Randi Wheeler**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 01/03/17 10:00 AM

Project: Pt. Pleasant - Ocean Road

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0008</i>		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM	
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0009</i>		
38-1229-0C09 Room 302 Bathroom Sink (45)									
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM	
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0010</i>		
38-1229-0C10 Faculty Dining Room Sink (35)									
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM	
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0011</i>		
38-1229-0C11 Room 143 Sink (34)									
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM	
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0012</i>		
38-1229-0C12 Water Fountain (33)									
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM	
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0013</i>		
38-1229-0C13 Water Fountain (32)									
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM	
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0014</i>		
38-1229-0C14 Water Fountain (31)									
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011700025
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Randi Wheeler**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 01/03/17 10:00 AM

Project: Pt. Pleasant - Ocean Road

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0015</i>	
38-1229-0C15 Girls Bathroom Sink (left)								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0016</i>	
38-1229-0C16 Boys Bathroom Sink (left)								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0017</i>	
38-1229-0C17 Girls Bathroom Sink (right)								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0018</i>	
38-1229-0C18 Boys Bathroom Sink (right)								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0019</i>	
38-1229-0C19 Water Fountain (30)								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0020</i>	
38-1229-0C20 Room 138 Sink (28)								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0021</i>	
38-1229-0C21 Room 137 Sink (27)								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011700025
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Randi Wheeler**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 01/03/17 10:00 AM

Project: Pt. Pleasant - Ocean Road

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0022</i>	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	2.55	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0023</i>	
38-1229-0C23 Room 136 Sink (26)								
200.8	Lead	1.02	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0024</i>	
38-1229-0C24 Room 135 Sink (24)								
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0025</i>	
38-1229-0C25 Room 134 Sink (23)								
200.8	Lead	1.21	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0026</i>	
38-1229-0C26 Room 164 Water Fountain (21)								
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0027</i>	
38-1229-0C27 Room 164 Bathroom Sink (22)								
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0028</i>	
38-1229-0C28 Room 167 Sink (20)								
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011700025
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Randi Wheeler**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 01/03/17 10:00 AM

Project: Pt. Pleasant - Ocean Road

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
38-1229-0C29 Room 167 Water Fountain (19)		12/29/2016		0029			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00 µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
38-1229-0C30 Room 170 Sink (17)		12/29/2016		0030			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00 µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
38-1229-0C31 Room 170 Bathroom Sink (18)		12/29/2016		0031			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00 µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
38-1229-0C32 Water Fountain (29)		12/29/2016		0032			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00 µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
38-1229-0C33 Room 132 Sink (15)		12/29/2016		0033			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00 µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
38-1229-0C34 Room 133 Sink (16)		12/29/2016		0034			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00 µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
38-1229-0C35 Room 131 Sink (14)		12/29/2016		0035			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00 µg/L	1/23/2017	CB	1/23/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011700025
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Randi Wheeler**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 01/03/17 10:00 AM

Project: Pt. Pleasant - Ocean Road

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
38-1229-0C36 Room 130 Sink (13)		12/29/2016		0036			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00 µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
38-1229-0C37 Water Fountain (12)		12/29/2016		0037			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00 µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
38-1229-0C38 Womens Faculty Bathroom Sink (10)		12/29/2016		0038			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	1.08	1.00 µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
38-1229-0C39 Room 129 Sink (11)		12/29/2016		0039			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00 µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
38-1229-0C40 Mens Faculty Bathroom Sink (9)		12/29/2016		0040			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00 µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
38-1229-0C41 Girls Bathroom by Main Entrance Sink (left)		12/29/2016		0041			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00 µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
38-1229-0C42 Girls Bathroom Sink by Main Entrance (right)		12/29/2016		0042			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00 µg/L	1/23/2017	CB	1/23/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011700025
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Randi Wheeler**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 01/03/17 10:00 AM

Project: Pt. Pleasant - Ocean Road

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0043</i>	
38-1229-0C43 Boys Bathroom near Main Entrance Sink (left)								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0044</i>	
38-1229-0C44 Boys Bathroom Sink near Main Entrance (right)								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0045</i>	
38-1229-0C45 Water Fountain (1)								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0046</i>	
38-1229-0C46 Water Fountain (2)								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0047</i>	
38-1229-0C47 Water Fountain (3)								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0048</i>	
38-1229-0C48 Sink in Therapy Room off of Gym								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	2.26	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0049</i>	
38-1229-0C49 Sink in Equipment Room off of Gym								
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	2.06	1.00	µg/L	1/23/2017	CB	1/23/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011700025
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Randi Wheeler**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 01/03/17 10:00 AM

Project: Pt. Pleasant - Ocean Road

Analytical Results

Client Sample Description		38-1229-0C50	Collected:		12/29/2016	Lab ID:		0050
		Nurses Office Bathroom Sink (8)						
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
Client Sample Description		38-1229-0C51	Collected:		12/29/2016	Lab ID:		0051
		Nurses Office Eyewash Sink (7)						
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
Client Sample Description		38-1229-0C52	Collected:		12/29/2016	Lab ID:		0052
		Main Office Sink (4)						
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
Client Sample Description		38-1229-0C53	Collected:		12/29/2016	Lab ID:		0053
		Main Office Mens Bathroom Sink (5)						
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
Client Sample Description		38-1229-0C54	Collected:		12/29/2016	Lab ID:		0054
		Main Office Womens Bathroom Sink (6)						
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
Client Sample Description		38-1229-0C55	Collected:		12/29/2016	Lab ID:		0055
		Room 210 Sink (61)						
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
Client Sample Description		38-1229-0C56	Collected:		12/29/2016	Lab ID:		0056
		Room 209 Sink (60)						
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.15	1.00	µg/L	1/23/2017	CB	1/23/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011700025
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Randi Wheeler**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 01/03/17 10:00 AM

Project: Pt. Pleasant - Ocean Road

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0057</i>	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	4.83	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0058</i>	
38-1229-0C57 Room 208 Sink (59)								
200.8	Lead	2.21	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0059</i>	
38-1229-0C58 Room 214 Sink (58)								
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0060</i>	
38-1229-0C59 Upstairs Water Fountain (56)								
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0061</i>	
38-1229-0C60 Room 217 Sink (57)								
200.8	Lead	1.01	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0062</i>	
38-1229-0C61 Room 207 Sink (55)								
200.8	Lead	1.55	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0063</i>	
38-1229-0C62 Room 206 Sink (54)								
200.8	Lead	1.79	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0063</i>	
38-1229-0C63 Library Sink (53)								
200.8	Lead	1.79	1.00	µg/L	1/23/2017	CB	1/23/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700025

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Randi Wheeler**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 01/03/17 10:00 AM

Project: Pt. Pleasant - Ocean Road

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0064</i>	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	1.21	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0065</i>	
Room 221 Sink (52)								
200.8	Lead	1.18	1.00	µg/L	1/23/2017	CB	1/24/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0066</i>	
Room 205 Sink (51)								
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0067</i>	
Water Fountain (49)								
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0067</i>	
Girls Bathroom Sink (top floor left)								
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0068</i>	
Girls Bathroom Sink (top floor right)								
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0069</i>	
Boys Bathroom Sink (top floor left)								
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM
<i>Client Sample Description</i>				<i>Collected:</i>	<i>12/29/2016</i>	<i>Lab ID:</i>	<i>0070</i>	
Boys Bathroom Sink (top floor right)								
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700025

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Randi Wheeler**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 01/03/17 10:00 AM

Project: Pt. Pleasant - Ocean Road

Analytical Results

Client Sample Description 38-1229-0C71 **Collected:** 12/29/2016 **Lab ID:** 0071
 Water Fountain (48)

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM

Client Sample Description 38-1229-0C72 **Collected:** 12/29/2016 **Lab ID:** 0072
 Room 203 Sink (47)

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.39	1.00	µg/L	1/23/2017	CB	1/23/2017	SM

Client Sample Description 38-1229-0C73 **Collected:** 12/29/2016 **Lab ID:** 0073
 Room 202 Sink (46)

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/23/2017	CB	1/23/2017	SM

Definitions:

ND - indicates that the analyte was not detected at the reporting limit
 RL - Reporting Limit (Analytical)